# DuPont<sup>™</sup>Suva® refrigerants

P-124

# DuPont HCFC-124

# **Properties, Uses, Storage, and Handling**

DuPont<sup>™</sup> Suva<sup>®</sup> refrigerants DuPont fire extinguishant

### **Table of Contents**

Introduction       1         Background       1         Hydrochlorofluorocarbon 124       1
Uses
Physical Properties 2
Chemical/Thermal Stability       2         Stability with Metals       2         Thermal Decomposition       5         Concerns if R-12 or R-114 and Refrigerants Containing       6         HCFC-124 Are Mixed       5
Materials Compatibility       6         Elastomers and Plastics       6         Desiccants       6         Refrigeration Lubricants       6
Safety9Inhalation Toxicity9Cardiac Sensitization9Skin and Eye Contact10Spills or Leaks10Storage Tanks10Filling and Charging Operations10Refrigerant Recovery Systems11
Air Monitors and Leak Detection       11         Types of Detectors       11         Nonselective Detectors       11         Halogen-Selective Detectors       11         Compound-Specific Detectors       12
Storage and Handling12Shipping in the United States12Handling Precautions for HCFC-12412Shipping Containers12
Recovery, Recycle, Reclamation, and Disposal12Recovery13Recycle13Reclamation13Disposal13

#### Introduction

#### Background

Chlorofluorocarbons (CFCs), which were developed over 60 years ago, have many unique properties. They are low in toxicity, nonflammable, noncorrosive, and compatible with other materials. In addition, they offer the thermodynamic and physical properties that make them ideal for a variety of uses. CFCs have been used as refrigerants; as blowing agents in the manufacture of insulation, packaging, and cushioning foams; as cleaning agents for metal and electronic components; and in many other applications.

#### Hydrochlorofluorocarbon 124

HCFC-124 is a component of blends intended to replace R-12 in refrigeration applications. It may also be used as a pure refrigerant to replace R-114 in limited specific applications. HCFC-124 also has potential utility as a fire extinguishant. It may be identified by any of the following names:

Hydrochlorofluorocarbon 124 2-chloro-1,1,1,2-tetrafluoroethane HCFC-124 Suva<sup>®</sup> 124 refrigerant FE-241 fire extinguishant

Table 1 gives the chemical name and formula for HCFC-124.

#### Uses

#### Refrigeration

HCFC-124 is a component of DuPont<sup>™</sup> Suva<sup>®</sup> MP39 and Suva<sup>®</sup> MP66 refrigerants. These refrigerants closely match the performance of R-12 and, along with Suva<sup>®</sup> 134a, are DuPont's primary replacements for R-12 and R-500 in a wide range of applications. R-12 and R-500 have been used in supermarkets, air conditioning, food service, and transport refrigeration. Suva<sup>®</sup> MP refrigerants offer equivalent or improved capacity and energy efficiency in these applications.

HCFC-124 may be used by itself as a pure refrigerant to replace R-114 in some applications, although its vapor pressure is somewhat higher than that of R-114. In addition, when replacing R-114 with HCFC-124, significantly higher refrigeration capacity will be encountered. This may result in electrical overload of the motor unless precautions are taken. The expansion device may also need to be modified.

#### Fire Suppression

DuPont is actively pursuing HCFC-124 as a transitional product to replace Halon 1301 and Halon 1211 in total flooding and streaming applications.

Product Information				
	Chemical Name	Formula	CAS Number	Molecular Weight
HCFC-124	2-chloro-1,1,1,2-tetrafluoroethane	CHCIFCF <sub>3</sub>	2837-89-0	136.48

Table 1

The DuPont Oval Logo, DuPont<sup>™</sup>, The miracles of science<sup>™</sup>, and Suva® are trademarks or registered trademarks of E.I. du Pont de Nemours and Company.

#### **Physical Properties**

Physical properties of HCFC-124 are shown in **Table 2**.

Pressure-enthalpy diagrams for HCFC-124 are shown in **Figures 1** and **2**.

Thermodynamic tables in English and SI units are available in Bulletins T-124-ENG (H-47755) and T-124-SI (H-47756).

#### **Chemical/Thermal Stability**

#### Stability with Metals

Stability tests for refrigerant with metals are typically performed in the presence of refrigeration lubricants. Results of sealed tube stability tests are available for R-12/mineral oil and alkylbenzene lubricants, which have shown long-term stability in contact with copper, steel, and aluminum in actual refrigeration systems. Mineral oils and alkylbenzenes are possible candidates for use with refrigerants containing HCFC-124. Tests with HCFC-based refrigerants in general show acceptable compatibility and stability with alkylbenzene lubricants. As can be seen in **Tables 3** and **4**, HCFC-124 is significantly more stable than CFC-114. This is indicated by the much lower chloride generation in the stability tests.

**Note:** Lubricant/refrigerant combinations shown throughout this report are for the purposes of comparing the stability and compatibility of different lubricants with HCFC-124. No recommendation is made or implied that these combinations will operate successfully in refrigeration systems.

Physical Property	Units	Value
Molecular Weight	(avg.)	136.48
Boiling Point at 1 atm	°C °F	-12.1 10.3
Critical Temperature	°C °F	122.2 252.0
Critical Pressure	kPa psia	3614 524.5
Critical Density	kg/m³ Ib/ft <sup>3</sup>	565 35.28
Liquid Density at 25°C (77°	F) kg/m <sup>3</sup> Ib/ft <sup>3</sup>	1401 87.6
Density, Satd. Vapor at –15°C (5°F)	kg/m³ Ib/ft <sup>3</sup>	6.88 0.43
Specific Heat Liquid at 25°0	C kJ/kg⋅K Btu/lb⋅°F	1.13 0.27
Specific Heat Vapor at 25°0 and 1 atm	C kJ/kg⋅K Btu/lb⋅°F	0.742 0.177
Vapor Pressure at 25°C	kPa psia	386 56
Heat of Vaporization at Boiling Point	kJ/kg Btu/lb	194 83.2
Thermal Conductivity at 25 Liquid	W/m⋅K	0.0722
Vapor at 1 atm	Btu/hr∙ft∙°F W/m∙K Btu/hr∙ft∙°F	0.0417 0.0106 0.0061
Viscosity at 25°C Liquid	mPa⋅s	0.299
Vapor at 1 atm	cP mPa⋅s cP	0.299 0.0120 0.0120
Flammability Limit in Air at 1 atm	vol%	None
Ozone Depletion Potential	(CFC-12 = 1)	0.02
Halocarbon Global Warming Potential	(CFC-11 = 1)	0.10
TSCA Inventory Status	Reported/Included?	Yes, consent orde
Inhalation Exposure Limit	AEL* (8 and 12 hr TWA)	1000

\*Acceptable Exposure Limit (AEL) is an airborne inhalation exposure limit established by DuPont that specifies time-weighted average concentrations to which nearly all workers may be repeatedly exposed without adverse effects.




Figure 1. Pressure-Enthalpy Diagram for HCFC-124 (English Units)




Figure 2. Pressure-Enthalpy Diagram for HCFC-124 (SI Units)

Table 3		
Compatibility	y with Metal Compressor Materials	

	Chloride Analysis, ppm		
	HCFC-124 (Alkylbenzene)	CFC-114 (Paraffinic Mineral Oil)	
Aluminum Impeller	3.7	45.3	
Copper Tube	0.2	30.3	
Titanium Tube	2.1	53.7	
Gray Cast Iron	0.4	43.0	
Steel Tubing	0.8	12.1	

Aged 14 days at 175°C

Table 4Chemical Stability			
	Average Chloride Ion Values, μg		
Lubricant	HCFC-124	CFC-114	
Naphthenic	120	531	
Alkylbenzene	105	1,039	
Paraffinic	166	798	

Aged 14 days at 175°C

Copper, steel, and aluminum coupons

#### Thermal Decomposition

Like R-12 and R-114, HCFC-124 will decompose when exposed to high temperatures from sources such as open flames or electric resistance heaters. Decomposition may produce toxic and irritating compounds such as hydrochloric and hydrofluoric acid and possibly carbonyl halides. The pungent odors released will irritate the nose and throat and generally force people to evacuate the area. Therefore, it is important to prevent decomposition by following DuPont recommendations for handling and use.

#### Concerns if R-12 or R-114 and Refrigerants Containing HCFC-124 Are Mixed

R-12 and R-114 and HCFC-124 are chemically compatible with each other; this means that they do *not* react with each other and form other compounds. However, when different refrigerants are mixed by accident or deliberately, they will form mixtures that are very difficult to separate. Therefore, mixtures of R-12 or R-114 and HCFC-124 containing refrigerants cannot be separated in on-site recycle machines or in the typical facilities of an off-site reclaimer. These mixtures will have to be disposed of by incineration.

Also, mixtures of R-12 or R-114 and HCFC-124 containing refrigerants will have performance properties different than either refrigerant alone. These properties may not be acceptable for your systems. We do not recommend mixing refrigerants in any system. First remove the R-12 or R-114 properly and then charge the new refrigerant.

#### **Materials Compatibility**

Because HCFC-124 will be used in different applications, it is important to review materials of construction for compatibility when designing new equipment, retrofitting existing equipment, or preparing storage and handling facilities. The compatibility data summarized here will include materials commonly used in refrigeration applications.

#### **Elastomers and Plastics**

It should be recognized that these data reflect compatibility in sealed tube tests, and that HCFC-124 compatibility in real systems can be influenced by the actual operating conditions, the nature of the polymers used, compounding formulations of the polymers, and the curing or vulcanization processes used to create the polymer. Elastomers should always be tested under actual operating conditions before reaching final conclusions about their suitability.

The rankings shown in Table 5 are based on samples of each polymer subjected to aging at room temperature for two weeks in HCFC-124 alone. Table 6 shows compatibility of HCFC-124 with various plastics using the same aging conditions. Physical properties of the test samples were determined before and after aging. The resulting ratings are based on zero (0) being best and two (2) being worst for the purposes of comparison. The factors included in the overall assessment of compatibility included:

- visual observations of material changes due to aging
- changes in weight and volume of the samples due to aging
- changes in hardness of the samples due to aging
- changes in flexural properties of the samples due to aging

#### Desiccants

In refrigeration systems, keeping the refrigerant and lubricant free of moisture is very important. Driers filled with moisture-adsorbing desiccant are typically used to prevent moisture accumulation.

Pure HCFC-124 is reported by UOP to be compatible with their XH-6 and XH-9 molecular sieve desiccants and by W. R. Grace to be compatible with their MS 592 or MS 594 molecular sieve desiccants. Equivalent molecular sieves produced by other manufacturers may also be used. Loose filled and compacted bead driers contain only molecular sieve desiccants, while solid core driers contain molecular sieves mixed with other materials. Consult the manufacturers of solid core driers for their recommendations.

Suva<sup>®</sup> refrigerant blends containing HCFC-124 plus other components may not be compatible with XH-6 molecular sieve desiccant. Refer to the appropriate DuPont bulletins for information on these refrigerants.

#### **Refrigeration Lubricants**

Most compressors require a lubricant to protect internal moving parts. The compressor manufacturer usually recommends the type of lubricant(s) and proper viscosity that should be used to ensure acceptable operation and equipment durability. Recommendations are based on several criteria, which can include lubricity, miscibility, compatibility with materials of construction, thermal stability, and compatibility with other lubricants. It is important to follow the manufacturers' recommendations for lubricants to be used with their equipment.

Polymer	Rating	Linear Swell, %	Weight Gain, %	Hardness Change
Natural Rubber	0	3	22	-7
Butyl Rubber	0	<1	8	-8
Nordel <sup>,</sup> EPDM	0	-1	3	-5
Neoprene CR	0	<1	3	-4
SBR	1	<1	6	-15
Nitrile Rubber NBR	0	<1	10	-7
	2	28	169	-17
Vamac EA	2*	32	175	-14
Hypalon <sup>,</sup> CSM	0	3	9	-5
Fluoroelastomers Viton A Viton B Viton GF Kalrez Fluorinated Silicone	2 2 2 2 2 2	16 23 25 19 17	57 85 88 47 81	-13 -34 -25  -16
Silicone	2	19	125	-12
Epichlorohydrin Homopolymer	0	-0.2	6	-4
Adiprene <sup>,</sup> U	2	29	172	-18
FA Polysulfide Thermoplastics Alcryn Santoprene Geolast Hytrel polyester	0 0 1 0	-1 7 1 8 8	3 38 12 70 36	-2 8 -7 -13 0
Gasketing Materials Cork Vegetable fiber		2 -0.2	134 34	_
Gylon <sup>,</sup> filled PTFE Armalon <sup>®</sup> PTFE felt	_	2 2	6 32	_

### Table 5Polymer Compatibility with HCFC-124

#### RATING:

"0"—both linear swell and hardness change are less than 10%

"1"—either swell OR hardness change greater than 10%

"2"-both swell AND hardness change greater than 10%

#### COMMENTS:

\*sample lost elasticity; did not return to original shape when deformed

#### **TEST CONDITIONS:**

Two weeks at room temperature; refrigerant only

Plastic	Rating	Weight Change, %
Polypropylene	1	2
Styron <sup>®</sup> polystyrene	1	6
Polyvinyl chloride PVC CPVC	0 0	0 <1
Fluorocarbon Teflon <sup>®</sup> PTFE Tefzel <sup>®</sup> ETFE PVDF	1 2 0	4 5 <1
Surlyn <sup>®</sup> ionomer	1	2
Lucite <sup>®</sup> acrylic	2*	_
Kralastic <sup>®</sup> ABS	2*	_
Ethocel <sup>®</sup> cellulosic	2*	40
Ероху	0	0
Delrin <sup>®</sup> acetal	0	1
Noryl <sup>®</sup> PPO	0	<1
Tuffak <sup>®</sup> PC	0	<1
Polyester Rynite <sup>®</sup> PET Valox <sup>®</sup> PBT Arylon <sup>®</sup> polyarylate Xydar <sup>®</sup> LCP	0 0 0 0	<1 <1 <1 0
Zytel <sup>®</sup> nylon	0	0
Polyimide Vespel <sup>®</sup> PI Ultem <sup>®</sup> PEI Torlan <sup>®</sup> PAI	0 0 0	1 0 0
Ryton <sup>®</sup> PPS	0	1
Polysulfone Polysulfone Radel <sup>®</sup> Polyarylsulfone	0 0	<1 0

 Table 6

 Compatibility of HCFC-124 with Plastics

Current lubricants used with R-12 and R-114 have nearly complete miscibility, which eases the problems of designing systems to allow lubricant return back to the compressor. Many refrigeration systems take advantage of this miscibility when considering lubricant return.

HCFC-124 exhibits less miscibility with common mineral oil lubricants used with R-12 or R-114. However, alkylbenzene appears to be a good lubricant candidate for HCFC-124.

Compressor and equipment manufacturers will recommend lubricants to use with their equipment. It would be difficult to summarize all possible lubricant candidates that may be screened by various equipment manufacturers. In addition, there will be continuing research and development of new lubricants, because the market for alternative refrigerants continues to stimulate other market areas.

**Table 7** shows a summary of miscibility tests done with an 80/20 volume mixture of refrigerant and lubricant over a wide range of temperatures, with visual inspection for phase separation as the tubes are slowly warmed. Alkylbenzene offers excellent miscibility with HCFC-124. This table does not show that any refrigerant/lubricant combination is acceptable, only whether the two appear to be miscible at the conditions shown.

#### RATING:

"0"-compatible by visual inspection and weight change

"1"—borderline by visual inspection or weight change

"2"-incompatible by visual inspection and weight change

#### COMMENTS:

\*sample dissolved

#### **TEST CONDITIONS:**

Two weeks at room temperature; refrigerant only




Table 7 Miscibility Summary (Temperature in °C)

#### Safety

Users of DuPont HCFC-124 should read and understand the DuPont Material Safety Data Sheet (MSDS). Copies of the HCFC-124 MSDS can be obtained at www.suva.dupont.com.

ASHRAE Classification = A1.

#### Inhalation Toxicity

HCFC-124 poses no acute or chronic hazard when it is handled in accordance with DuPont recommen-dations and when exposures are maintained below recommended limits, such as the DuPont Acceptable Exposure Limit (AEL) of 1000 ppm, 8 or 12 hour time weighted average (TWA).

An AEL is an airborne exposure limit established by DuPont that specifies time-weighted average airborne concentrations to which nearly all workers may be repeatedly exposed during a 40-hr work week without adverse effects.

Like R-114, exposure above the recommended limit to the vapors of HCFC-124 by inhalation may cause human health effects that can include temporary nervous system depression with anesthetic effects such as dizziness, headache, confusion, loss of coordination, and even loss of consciousness. Higher exposures to the vapors may cause temporary alteration of the heart's electrical activity with irregular pulse, palpitations, or inadequate circulation. Death can occur from gross overexposure. Intentional misuse or deliberate inhalation of HCFC-124 vapors may cause death without warning. This practice is extremely dangerous.

If you are exposed to HCFC-124 vapors and experience any of the above symptoms, move immediately to fresh air and seek medical attention.

#### **Cardiac Sensitization**

An effect that occurs with most hydrocarbons and halocarbons at high concentrations is that the human heart can become sensitized to adrenalin, leading to cardiac irregularities and even cardiac arrest. The likelihood of these cardiac problems increases if you are under physical or emotional stress. HCFC-124 can cause these responses well above the AEL.

If you are exposed to very high concentrations of HCFC-124, move immediately from the area and seek medical attention as a precaution. DO NOT attempt to remain in the area to fix a leak or perform other duties—the effects of over-exposure can be very sudden.

Medical attention must be given immediately if someone is having symptoms of overexposure to HCFC-124. DO NOT treat the patient with drugs such as epinephrine, because these drugs could increase the risk of cardiac problems. If the person is having trouble breathing, administer oxygen. If breathing has stopped, give artificial respiration immediately.

#### Skin and Eye Contact

At room temperature, HCFC-124 vapors have little or no effect on the skin or eyes. However, in liquid form, HCFC-124 can cause frostbite. If contact with liquid does occur, soak the exposed areas in lukewarm water, not cold or hot. In all cases, seek medical attention as soon as possible.

Always wear protective clothing when there is a risk of exposure to liquid refrigerants. Where splashing of refrigerant may occur, always wear eye protection and a face shield.

#### Spills or Leaks

If a large release of vapor occurs, such as from a large spill or leak, the vapors may concentrate near the floor or in low elevation areas, which can displace the oxygen needed for life, resulting in suffocation.

Evacuate everyone until the area has been well ventilated. Re-enter the area only while using self-contained breathing apparatus. Use blowers or fans to circulate the air at floor or low levels.

Always use self-contained breathing apparatus or an air-line respirator when entering tanks or other areas where vapors might exist. Use the buddy system (a second employee stationed outside the tank) and a lifeline. Refer to the Material Safety Data Sheet (MSDS) for HCFC-124 for more complete safety information.

HCFC-124 has virtually no odor and, therefore, can be extremely difficult to detect in enclosed areas. Frequent leak checks and the installation of permanent leak detectors may be necessary for enclosed areas or machinery rooms. Refer to ASHRAE Standards 15 and 34 for machinery room requirements.

To ensure safety when using HCFC-124 refrigerant in enclosed areas:

- Route relief and purge vent piping outdoors, away from air intakes.
- Make certain the area is well ventilated at all times; use auxiliary ventilation, if necessary, to remove vapors.

- Make sure the work area is free of vapors prior to beginning any work.
- Install air monitoring equipment to detect leaks.
- Equipment should *never* be leak tested with a pressurized mixture of air and HCFC-124. A mixture of dry nitrogen and HCFC-124 can be used.

#### Storage Tanks

- Bulk storage tanks should be evacuated prior to initial filling and should *never* be under positive air pressure.
- Tanks should not be pressurized above 1.5 times the normal working pressure with HCFC-124 refrigerant. Relief devices on either the tanks or refrigerant supply system should be verified to be set below this pressure.
- Tank pressures should be monitored routinely to look for accumulation of air.
- Air lines should *never* be connected to refrigerant storage tanks.

#### Filling and Charging Operations

- Before starting work, read the DuPont Material Safety Data Sheet (MSDS) for HCFC-124.
- Before evacuating cylinders or refrigeration equipment, any remaining refrigerant should be removed using a recovery system.
- Vacuum pump discharge lines should be free of restrictions that could increase discharge pressures.
- Cylinders or refrigeration equipment should normally be evacuated at the start of filling and never be under positive air pressure.
- Filled cylinders should periodically be analyzed for air (nonabsorbable gases or NAGs).

#### **Refrigerant Recovery Systems**

Efficient recovery of refrigerant from equipment or containers requires evacuation at the end of the recovery cycle. Suction lines to a recovery com-pressor should be periodically checked for leaks to prevent compressing air into the recovery cylinder during evacuation. In addition, the recovery cylinder pressure should be monitored, and evacuation stopped in the event of a rapid pressure rise, indicating the presence of noncondensable air. The recovery cylinder contents should then be analyzed for NAG, and the recovery system leak checked if air is present. Do not evacuate a refrigeration system that has a major leak.

#### **Air Monitors and Leak Detection**

Service personnel have used leak detection equipment for years when servicing equipment. Leak detectors exist not only for pinpointing specific leaks, but also for monitoring an entire room on a continual basis. American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE) Standard 15 requires air monitors in refrigeration machinery rooms as defined in the Standard. In conformance with the Standard, an air monitor capable of measuring 0–1500 ppm of HCFC-124 *may* be required for indoor installations. The user should check ASHRAE Standard 15 to determine what is required for the particular application.

There are several reasons for leak pinpointing or area monitoring, including:

- · conservation of refrigerant
- protection of employees
- detection of fugitive or small emissions
- protection of equipment

Leak detectors can be placed into two broad categories: leak pinpointers and area monitors. Before purchasing a monitor or pinpointer, several criteria should be considered, which include sensitivity, detection limits, and selectivity.

#### Types of Detectors

Using selectivity as a criterion, leak detectors can be placed into one of three categories: nonselective, halogen-selective, or compound-specific. In general, as the specificity of the monitor increases, so will the complexity and cost.

A different technology that can be employed to find leaks is by using a dye or fluorescent additive that is placed in the refrigeration system and emitted with the leaking refrigerant and lubricant.

A detailed discussion of leak detection, along with a list of manufacturers of leak detection equipment, can be found in DuPont Bulletin ARTD-27 (H-31753-2).

#### **Nonselective Detectors**

Nonselective detectors are those that will detect any type of emission or vapor present, regardless of its chemical composition. These detectors are typically quite simple to use, very rugged, inexpensive, and almost always portable. However, their inability to be calibrated, long-term drift, lack of selectivity, and lack of sensitivity limit their use for area monitoring.

Some nonselective detectors designed for use with R-114 may have a lower sensitivity when used with HCFC-124 refrigerant. However, newly designed detectors with good sensitivity for HCFCs are now available. Be sure to consult with the manufacturer before selecting or using a nonselective detector with HCFC-124 refrigerant.

#### **Halogen-Selective Detectors**

Halogen-selective detectors use a specialized sensor that allows the monitor to detect compounds containing fluorine, chlorine, bromine, and iodine, without interference from other species. The major advantage of such a detector is a reduction in the number of "nuisance alarms"—false alarms caused by the presence of some compound in the area other than the target compound.

These detectors are typically easy to use, feature higher sensitivity than the nonselective detectors (detection limits are typically <5 ppm when used as an area monitor and <0.05 oz/yr [<1.4 g/yr] when used as a leak pinpointer) and are very durable. In addition, due to the partial specificity of the detector, these instruments can be easily calibrated.

#### **Compound-Specific Detectors**

The most complex detectors, which are also the most expensive, are compound-specific detectors. These units are typically capable of detecting the presence of a single compound, without interference from other compounds. In an area where different refrigerant mixtures are used, these detectors may offer more specificity than is needed for normal leak management. Discuss these issues with the equipment manufacturer before making a purchase decision.

#### Storage and Handling Shipping in the United States

HCFC-124 is a liquefied compressed gas. According to the U.S. Department of Transportation (DOT), a nonflammable compressed gas is defined as a nonflammable material having an absolute pressure greater than 40 psia at 21°C (70°F) and/or an absolute pressure greater than 104 psia at 54°C (130°F).

The appropriate DOT designations are as follows:

DOT Proper Shipping Name	LIQUEFIED GAS N.O.S. (CHLOROTETRAFLUOROETHANE)	
Hazard Class	2.2	
UN Number	1021	
DOT/IMO Labels	NONFLAMMABLE GAS	

#### Handling Precautions for HCFC-124 Shipping Containers

The following rules for handling HCFC-124 containers are strongly recommended:

- Use personal protective equipment, such as side shield safety glasses, gloves, and safety shoes when handling containers.
- Avoid skin contact with HCFC-124 as it may cause frostbite.
- Never heat a container to temperatures higher than 52°C (125°F).
- Never apply direct flame or live steam to a container or valve.

- Never refill disposable cylinders with anything. The shipment of refilled disposable cylinders is prohibited by DOT regulations.
- Never refill returnable cylinders without DuPont consent. DOT regulations forbid transportation of returnable cylinders refilled without DuPont authorization.
- Never use a lifting magnet or sling (rope or chain) when handling containers. A crane may be used when a safe cradle or platform is used to hold the container.
- Never use containers as rollers, supports, or for any purpose other than originally intended.
- Protect containers from any object that will result in a cut or other abrasion in the surface of the metal.
- Never tamper with the safety devices in the valves or containers.
- Never attempt to repair or alter containers or valves.
- Never force connections that do not fit. Make sure the threads on the regulators or other auxiliary equipment are the same as those on the container valve outlets.
- Keep valves tightly closed and valve caps and hoods in place when the containers are not in use.
- Store containers under a roof to protect them from weather extremes.
- Use a vapor recovery system to collect vapors from lines after unloading.

## **Recovery, Recycle, Reclamation, and Disposal**

Responsible use of HCFC-124 requires that the product be recovered for reuse or disposal whenever possible. DuPont purchases used refrigerant for reclamation through its distributor networks in the United States, Canada, and Europe. In the United States, Suva® 124 refrigerant is accepted as part of this program. Recovery and reuse of refrigerant makes sense from an environmental and economic standpoint. In addition, the U.S. Clean Air Act prohibits known venting of CFC, HCFC, and HFC refrigerants during the maintenance, servicing, or disposal of refrigeration equipment.

#### Recovery

Recovery refers to the removal of refrigerant from equipment and collection in an appropriate container. As defined by the Air Conditioning and Refrigeration Institute (ARI), recovery does not involve processing or analysis of the refrigerants. HCFC-124 may be recovered from refrigeration equipment using permanent onsite equipment or many of the portable recovery devices now available in the marketplace. The portable devices contain a small compressor and some have an air-cooled condenser. In many, the recovery cylinder serves as the condenser. They may be used for vapor (and in some cases, liquid) recovery. At the end of the recovery cycle, the system is evacuated thoroughly to remove vapors. In the United States, the Environmental Protection Agency (EPA) sets standards for recovery equipment. Before purchasing a specific recovery unit, check with the manufacturer to be sure that it contains proper materials of construction and lubricant for the refrigerants you intend to recover.

#### Recycle

Refrigerant recycle refers to reducing the contaminant levels in used refrigerants by passing the refrigerants through devices that separate out or reduce the amount of lubricant, water, acidity, and particulates. Recycle is usually a field or shop procedure with no analytical testing of refrigerant. HCFC-124 may be recycled using many of the devices now on the market. In the United States, the EPA sets standards for these devices. Recycle is already standard practice in many areas of the commercial refrigeration industry. Consult with the manufacturer before specifying a recycle device for any refrigerant.

#### Reclamation

Reclamation refers to the reprocessing of used refrigerant to new product specifications. Quality of the reclaimed product is verified by chemical analysis. In the United States, Suva® 124 refrigerant is included in DuPont's refrigerant reclamation program. Contact DuPont or one of our authorized distributors for further information.

Reclamation offers advantages over on-site refrigerant recycling procedures, because recycling systems cannot guarantee complete removal of all contaminants. Putting refrigerants that do not meet new product specifications into expensive equipment may cause damage.

#### Disposal

Disposal refers to the destruction of used refrigerant. Disposal may be necessary when the refrigerant has become badly contaminated with other products and no longer meets the acceptance specifications of reclaimers. Although DuPont does not accept severely contaminated refrigerant for disposal, licensed waste disposal firms are available. Be sure to check the qualifications of any firm before sending them used refrigerants.

#### **For Further Information:**

DuPont Fluorochemicals Wilmington, DE 19880-0711 (800) 235-SUVA www.suva.dupont.com

#### Europe

DuPont de Nemours International S.A. 2 Chemin du Pavillon P.O. Box 50 CH-1218 Le Grand-Saconnex Geneva, Switzerland 41-22-717-5111

#### Canada

DuPont Canada, Inc. P.O. Box 2200, Streetsville Mississauga, Ontario Canada L5M 2H3 (905) 821-3300

#### Mexico

DuPont, S.A. de C.V. Homero 206 Col. Chapultepec Morales C.P. 11570 Mexico, D.F. 52-5-722-1100

#### South America

DuPont do Brasil S.A. Alameda Itapecuru, 506 Alphaville 06454-080 Barueri São Paulo, Brazil 55-11-7266-8263

DuPont Argentina S.A. Casilla Correo 1888 Correo Central 1000 Buenos Aires, Argentina 54-1-311-8167

#### Pacific

DuPont Australia P.O. Box 930 North Sydney, NSW 2060 Australia 61-2-99236111

#### Japan

Mitsui DuPont Fluorochemicals Co., Ltd. Chiyoda Honsha Bldg. 5-18, 1-Chome Sarugakucho Chiyoda-Ku, Tokyo 101-0064 Japan 81-3-5281-5805

#### Asia

DuPont Taiwan P.O. Box 81-777 Taipei, Taiwan 886-2-514-4400

DuPont China Limited P.O. Box TST 98851 1122 New World Office Bldg. (East Wing) Tsim Sha Tsui Kowloon, Hong Kong Phone: 852-734-5398 Fax: 852-236-83516

DuPont Thailand Ltd. 9-11 Floor, Yada Bldg. 56 Silom Road Suriyawongse, Bankrak Bangkok 10500 Phone: 66-2-238-0026 Fax: 66-2-238-4396

DuPont China Ltd. Rm. 1704, Union Bldg. 100 Yenan Rd. East Shanghai, PR China 200 002 Phone: 86-21-328-3738 Telex: 33448 DCLSH CN Fax: 86-21-320-2304 DuPont Far East Inc. 6th Floor Bangunan Samudra No. 1 JLN. Kontraktor U1/14, SEK U1 Hicom-Glenmarie Industrial Park 40150 Shah Alam, Selangor Malaysia Phone 60-3-517-2534

DuPont Korea Inc. 4/5th Floor, Asia Tower #726, Yeoksam-dong, Kangnam-ku Seoul, 135-082, Korea 82-2-721-5114

DuPont Singapore Pte. Ltd. 1 Maritime Square #07 01 World Trade Centre Singapore 0409 65-273-2244

DuPont Far East, Philippines 8th Floor, Solid Bank Bldg. 777 Paseo de Roxas Makati, Metro Manila Philippines Phone: 63-2-818-9911 Fax: 63-2-818-9659

DuPont Far East Inc. 7A Murray's Gate Road Alwarpet Madras, 600 018, India 91-44-454-029

DuPont Far East Inc.—Pakistan 9 Khayaban-E-Shaheen Defence Phase 5 Karachi, Pakistan 92-21-533-350

DuPont Far East Inc. P.O. Box 2553/Jkt Jakarta 10001, Indonesia 62-21-517-800

The information contained herein is based on technical data and tests which we believe to be reliable and is intended for use by persons having technical skill, at their own discretion and risk. Because conditions of use are outside of DuPont control, we can assume no liability for results obtained or damages incurred through the application of the data presented.

Copyright © 2005 DuPont or its affiliates. All rights reserved. The DuPont Oval Logo, DuPont<sup>™</sup>, The miracles of science<sup>™</sup> and Suva<sup>®</sup> are registered trademarks or trademarks of DuPont or its affiliates.

NO PART OF THIS MATERIAL MAY BE REPRODUCED, STORED IN A RETRIEVAL SYSTEM OR TRANS-MITTED IN ANY FORM OR BY ANY MEANS ELECTRONIC, MECHANICAL, PHOTOCOPYING, RECORD-ING OR OTHERWISE WITHOUT THE PRIOR WRITTEN PERMISSION OF DUPONT.



(4/05) 246022 Printed in U.S.A. [Replaces: H-62445-1] Reorder No.: H-62445-2

The miracles of science™